

RIVERHEAD WATER DISTRICT

PLANT NO. 4 LIME SYSTEM REPLACEMENT

PROJECT NO.: RDWD 1801

H2M PROJECT NO.: RDWD 1801

BID DATE: MARCH 22, 2018 (NO CHANGE)

To All Prospective Bidders:

This addendum is hereby made part of the contract documents for the above Contract. Please note the revisions described herein and submit bids accordingly. Acknowledge receipt of this addendum in the Proposal Documents.

MODIFICATIONS

Item 1. Proposed Lime Storage Tank

- A. The Riverhead Water District will accept a conical bottom in lieu of a dished bottom as stated in the Specifications and as shown on the Plans. Specification 444459.13 shall be revised as below.
- B. Section 444459.13 – Lime Treatment System
 - a. Replace Section 444459.13, paragraph 2.1A in its entirety with the following:
 “2.1 A. – General Description: Solution tank shall be 5’-6” in diameter and 4’-0” feet high exclusive of dished **or conical** bottom. Nominal capacity 800-gallon tank wall shall be of one piece construction. Provide flat hinged tank cover for manually charging lime to tank and all required openings. Four (4) sturdy legs shall be welded to the tank bottom to support the tank above floor. Provide enough clearance for installation of drain piping and associated drain equipment.
 - b. Replace Section 444459.13, paragraph 2.1B in its entirety with the following:
 “2.1 B. – Manufacturer:
 - 1. Highland Tank, Stoystown, PA
 - 2. Sims Steel, Lindenhurst, NY
 - 3. Specifically Approved equal.
- C. The Riverhead Water District will accept a Fiberglass Reinforced Plastic tank which meets the requirements of AWWA Standard D120-09 as a substitute for a steel tank if proven to be an equal in all other aspects of the plans and specifications. “Alternate Item 2” and “Total Alternate Bid B” have been added to the revised proposal sheets, attached with this addendum. It should be noted that failure to submit a price for “Alternate Item 2” and “Total Alternate Bid B” does not mean forfeiture of the “Total Base Bid” or “Total Alternate Bid A.”
 - a. **Section 004116** should be replaced with the attached revised proposal sheets and should be filled in by each prospective bidder and submitted with the bid.

This addendum includes the following attachment:

Attachment

Section 004116 – Proposal (Revised)

Pages

4

ADDENDUM NO. 1



DATE: March 19, 2018

To verify receipt of this Addendum, the contractor must sign and date this sheet and return immediately via fax or email. **A copy shall also be included with the bid submission documents.**

To: Steven Mirra, H2M
Fax No.: (631) 694-4122
Email: smirra@h2m.com

Name: _____
(Please Print)

Signature: _____

Company: _____

Date: _____

Board:

The undersigned hereby offers to furnish all labor, equipment, materials and appurtenances for **Plant No. 4 Lime System Replacement**, all in accordance with the plans and specifications prepared by H2M architects + engineers for the following unit and lump sum prices:

ITEM 1 - MOBILIZATION AND DEMOBILIZATION

For mobilization, demobilization, and site restoration, as specified.

LUMP SUM: _____ (\$ _____)
DOLLARS

ITEM 2 – REMOVAL AND DISPOSAL OF EXISTING LIME STORAGE TANK & ACCESSORIES

For all labor, materials and equipment necessary for removing and disposing of the existing 1,000-gallon aboveground lime storage tank, mixers, pumps, piping and associated equipment as shown on the Plans and/or as described in the Specifications.

LUMP SUM: _____ (\$ _____)
DOLLARS

ITEM 3 – NEW ABOVEGROUND LIME STORAGE TANK – STEEL

For all labor, materials and equipment necessary for the furnishing and installing of a new 800-gallon aboveground steel lime storage tank and mixer as shown on the Plans and/or as described in the Specifications.

LUMP SUM: _____ (\$ _____)
DOLLARS

ITEM 4 – NEW LIME TREATMENT SYSTEM

For all labor, materials and equipment necessary for the furnishing and installing of a new lime treatment system including new chemical treatment pumps, all piping, valves, and fittings, and chemical signage as shown on the Plans and/or as described in the Specifications.

LUMP SUM: _____ (\$ _____)
DOLLARS

ITEM 5 - CASH ALLOWANCES

For all cash allowances for additional work, as specified in Section 012100 – Allowances.

LUMP SUM: Five Thousand & 00/100 _____ (\$ 5,000.00)
(Forced Bid Amount of \$5,000.00) DOLLARS

ITEM 6 - PROJECT RECORD DOCUMENTS

For furnishing project record documents, as-builts, and operation and maintenance manuals as described in the specification.

LUMP SUM: _____ (\$ _____)
(Minimum Bid of \$1,000.00) DOLLARS

ALT. ITEM 1 – NEW DUST COLLECTION AND EXHAUST SYSTEM

For all labor, materials and equipment necessary for the furnishing and installation of a new dust collection and exhaust system including complete electrical scope as shown on the Plans and/or as described in the Specifications.

LUMP SUM: _____ (\$ _____)
DOLLARS

ALT. ITEM 2 – NEW ABOVEGROUND LIME STORAGE TANK – FRP

For all labor, materials and equipment necessary for the furnishing and installing of a new 800-gallon aboveground fiberglass reinforced plastic (FRP) lime storage tank and mixer. FRP tank shall meet the requirements of AWWA Standard D120-09.

LUMP SUM: _____ (\$ _____)
DOLLARS

TOTAL BASE BID (Sum of Items 1-6)

DOLLARS (\$ _____)

TOTAL ALTERNATE BID A (Sum of Items 1-6 and Alt. Item 1)

DOLLARS (\$ _____)

TOTAL ALTERNATE BID B (Sum of Items 1-2, 4-6 and Alt. Items 1 and 2)

DOLLARS (\$ _____)

The Board of the Riverhead Water District reserves the right to award this contract based on either the total bid or any combination of bid items, as may be in the best interest of the Riverhead Water District. The award shall be made to the lowest responsible bidder based upon the bid items awarded. The Board reserves the right to reject any or all bids. The Board reserves the right to award this contract within forty-five (45) days of the bid opening.

Within ten (10) consecutive calendar days after the date of the Notice of Award, the bidder shall execute the contract and furnish the required bonds and insurances. The Notice to Proceed will be issued after the contract has been executed by the Owner.

All work shown and specified in the contract documents and included in this bid shall be completed within seventy five (75) consecutive calendar days from the date of the Notice to Proceed.

Failure of the contractor to complete all work within the specified time will subject him to liquidated damages as set forth in the contract, in the sum of five hundred dollars (\$500.00) per day, commencing with the 61st day from the date of the Notice to Proceed.

In addition to liquidated damages, specific damages will be assessed and deducted from amounts otherwise due the contractor for additional inspection and contract management time required to be expended by the Engineer should the project be completed beyond the contract completion date. Such deduction shall be in accordance with the billing rates and fees established between H2M and the Riverhead Water District.

Each bidder shall submit with its bid a separate sealed list that names each subcontractor that the bidder will use to perform work on the contract, and the agreed-upon amount to be paid to each, for: I) plumbing and gas fitting, II) steam heating, hot water heating, ventilating and air conditioning apparatus, and III) electric wiring and standard illuminating fixtures. After the low bid is announced, the sealed list of subcontractors submitted with such low bid shall be opened and the names of such subcontractors shall be announced, and thereafter any change of subcontractor or agreed-upon amount to be paid to each shall require the approval of the Owner, upon a showing presented to the Owner of legitimate construction need for such change, which shall be open to public inspection. Legitimate construction need shall include, but not be limited to, a change in project specifications, a change in construction material costs, a change to subcontractor status as determined pursuant to paragraph (E) of subdivision two (2) of section two hundred twenty-two (222) of the labor law, or the subcontractor has become otherwise unwilling, unable, or unavailable to perform the subcontract. The sealed lists of subcontractors submitted by all other bidders shall be returned to them unopened after the contract award.

The contractor shall coordinate all work with the Owner to minimize disturbances to Owner operations.

The bidder represents herewith that he is aware of the working conditions, has carefully reviewed the proposal and specifications, has checked and certifies the accuracy of the bid.

The undersigned hereby acknowledges receipt of the following addenda (if any):

ADDENDUM NO.	DATED
_____	_____
_____	_____
_____	_____

Each proposal shall be accompanied by either a certified check drawn on a solvent bank with an office in the State of New York, or a bid bond equal to five percent (5%) of the total amount of the bid and payable to the Riverhead Water District. The certified check or bid bond shall specify which contract it accompanies.

**SECURITY ENCLOSED FOR THIS SECTION
(BASE BID PLUS CONTINGENCY ITEMS)**

**YES / NO
(Circle One)**

PROPOSAL CERTIFICATION

This Bid is hereby submitted by:

BIDDER: _____

BIDDER'S ADDRESS: _____

SIGNED BY: _____ TITLE: _____

PRINT NAME: _____ DATE: _____

FEDERAL I.D. NO. OR
SOCIAL SECURITY NO.: _____

Telephone number where the contractor or a competent representative can accept a telephone message and provide a reasonable reply as soon as possible, but within 24 hours of being contacted.

DAY: _____ NIGHT: _____

EMERGENCY: _____ FAX: _____

EMAIL: _____

Acknowledgement that the Qualification of Bidders section has been fully completed/executed.

SIGNATURE	PRINT NAME	TITLE	DATE
_____	_____	_____	_____

END OF SECTION 004116