

TOWN OF RIVERHEAD

Resolution # 943

**AWARDS BID – CONSTRUCTION OF PRE-STRESSED GROUND  
STORAGE TANK AT PLANT NO. 15  
RIVERHEAD WATER DISTRICT**

Councilwoman Giglio offered the following resolution,

which was seconded by Councilman Hubbard

**WHEREAS**, this Town Board did authorize the advertisement for bids for Construction of Pre-Stressed Ground Storage Tank at Plant No. 15 of the Riverhead Water District, and

**WHEREAS**, all bids received were opened and read aloud on the date and time advertised in the notice, and

**WHEREAS**, H2M Group, consulting engineers to the Riverhead Water District, by attached letter dated December 8, 2017 did recommend that the bid be awarded to DN Tanks, Inc. of Wakefield, Massachusetts, for the total alternate bid amount of \$2,334,646.00.

**NOW, THEREFORE, BE IT RESOLVED**, that the bid Construction of Pre-Stressed Ground Storage Tank at Plant No. 15 of the Riverhead Water District, be and is hereby awarded to:

DN Tanks, Inc.  
Wakefield, Massachusetts  
In the total alternate bid amount of \$2,334,646.00

and be it further

**RESOLVED**, that DN Tanks, Inc. shall post a bond in the amount of the total bid of \$2,334,646.00, and be it further

**RESOLVED**, that the Town Clerk forward certified copy of this resolution to the above named contractor, and be it further

**RESOLVED**, that the Town Clerk is hereby authorized to return to all unsuccessful bidders their respective bid security, and be it further

**RESOLVED**, that pursuant to this bid award, the Town Supervisor be and is hereby authorized to execute a contract with DN Tanks, Inc. and be it further

**RESOLVED**, that upon completion of fully executed contracts and the filing of said contract with the Town Clerk, the Town Clerk is hereby authorized to release to the successful bidder the bidder's bid security.

**BE IT FURTHER RESOLVED**, that all Town Hall Departments may review and obtain a copy of this resolution from the electronic storage device and if needed, a certified copy of same may be obtained from the Office of the Town Clerk.

**THE VOTE**

Hubbard Yes No      Giglio Yes No  
Wooten Yes No      Dunleavy Yes No  
Walter Yes No

The Resolution Was  Thereupon Duly Declared Adopted



water

538 Broad Hollow Road, 4<sup>th</sup> Floor East Tel 631.756.8000  
Melville, NY 11747 Fax 631.694.4122

December 8, 2017

Town Board  
Town of Riverhead  
200 Howell Avenue  
Riverhead, New York 11901

**Re: Riverhead Water District  
Construction of Pre-Stressed Ground Storage Tank at Plant No. 15  
Contract T – Tank Construction  
H2M Project No.: RDWD 17-02**

Dear Board Members:

On Thursday December 7, 2017, bids were received by the Town of Riverhead for the above referenced project. A total of two (2) bids were submitted with the low bid being submitted by DN Tanks, Inc. of Wakefield, Massachusetts for a total base bid amount of \$2,438,742.00 and a total alternate bid amount of \$2,334,646.00. A copy of the bid tabulation sheet is enclosed for your records.


Please note that both the base and alternate bids included provisions for a 2.0 MG concrete ground storage tank. The base bid required that the dimensions of the tank to be the following: 120' diameter; 6' bury depth; 24' side water depth. As part of the alternate bid, the Contractor's were permitted to modify the dimensions to provide the most cost efficient 2.0 MG concrete ground storage tank. As part of the alternate, the low bidder modified the dimensions to the following: 108.5' diameter; 6' bury depth; 29' side water depth. Please note that both tanks have the same water capacity and the alternate bid conforms to the requirements of the District for proper operation.

We have investigated the qualifications submitted by the low bidder and have found him to be a qualified and responsible contractor. DN Tanks, Inc. has successfully completed similar projects for various water utilities across Long Island over the past few years. It is our opinion that DN Tanks, Inc. is qualified and his bid prices are fair and reasonable. Therefore, we recommend that the contract be awarded to DN Tanks, Inc. for the total alternate bid amount of \$2,334,646.00.

Should you have any questions regarding this recommendation, please contact our office.

Very truly yours,

**H2M architects + engineers**



John R. Collins, P.E.  
Senior Project Engineer

Enclosure: Bid Tabulation Sheet

cc: Supervisor Sean Walter  
Karen Levasseur, Town Board Coordinator  
Supt. Mark Conklin  
Richard Ehlers, Esq.

CLIENT NAME: Riverhead Water District

PROJECT TITLE: Ground Storage Tank at Plant No. 15 - Contract T

PROJECT NO.: RDWD 1702

BID DATE: December 7, 2017 - 2:00 p.m.

ITEM NO.	DESCRIPTION	UNITS	BIDDER	
			TOTAL PRICE	TOTAL PRICE
1	MOBILIZATION AND DEMOBILIZATION	LS	\$104,614.00	\$134,000.00
2A	SITE CLEARING	LS	33,334.00	32,000.00
2B	EARTHWORK	LS	386,014.00	390,000.00
2C	EARTHWORK (ALTERNATE)	LS	375,318.00	382,000.00
3A	NEW GROUND STORAGE TANK	LS	1,849,800.00	2,287,000.00
3B	NEW GROUND STORAGE TANK (ALTERNATE)	LS	1,756,400.00	2,072,000.00
4	DISINFECTION AND WATER QUALITY SAMPLING	LS	8,299.00	3,000.00
5A	CASH ALLOWANCES - QUALITY CONTROL TESTING	LS	25,000.00	25,000.00
5B	CASH ALLOWANCES - ADDITIONAL/UNFORSEEN WORK	LS	25,000.00	25,000.00
6	PROJECT RECORD DOCUMENTS	LS	6,681.00	5,000.00
TOTAL BASE BID (SUM OF ITEMS 1-2B, 3A, 4-6):			\$2,438,742.00*	\$2,901,000.00
TOTAL ALTERNATE BID (SUM OF ITEMS 1-2A, 2C, 3B, 4-6):			\$2,334,646.00**	\$2,678,000.00

\*Contractor indicated an incorrect amount of \$2,438,942.00 on proposal sheets.

\*\*Contractor indicated an incorrect amount of \$2,334,846.00 on proposal sheets.

BIDDER	BIDDER
DN Tanks, Inc. Wakefield, MA 5% BB	Preload, LLC Louisville, KY 5% BB